

# Washington State Register

April 7, 1999

MRR

OLYMPIA, WASHINGTON

ISSUE 99-07



## IN THIS ISSUE

PROPERTY OF  
APR 08 1999  
WASHINGTON STATE  
LAW LIBRARY

Agriculture, Department of  
Assistance Programs, Division of  
Basic Health Plan  
Bates Technical College  
Bellingham Technical College  
Benton Clean Air Authority  
Blueberry Commission  
Board of Natural Resources  
Community and Technical Colleges,  
State Board for  
Community, Trade and Economic Development,  
Department of  
Convention and Trade Center  
Corrections, Department of  
Ecology, Department of  
Economic Services Administration  
Edmonds Community College  
Education, State Board of  
Engineers and Land Surveyors, Board of  
Registration for Professional  
Financial Institutions, Department of  
Financial Management, Office of  
Fish and Wildlife, Department of  
Forest Practices Board  
Gambling Commission  
Governor's Task Force on School-to-Work  
Transition  
Governor, Office of the  
Health Care Authority  
Health, Department of  
Indeterminate Sentence Review Board  
Insurance Commissioner's Office

Interagency Integrated Pest Management  
Coordinating Committee  
Labor and Industries, Department of  
Lake Washington Technical College  
Library Commission  
Library, Washington State  
Licensing, Department of  
Liquor Control Board  
Medical Assistance Administration  
Natural Resources, Department of  
Peninsula College  
Pierce College  
Plumbers, Advisory Board of  
Public Employees Benefits Board  
Puget Sound Air Pollution Control Agency  
Retirement Systems, Department of  
Revenue, Department of  
Secretary of State  
Shoreline Community College  
Skagit Valley College  
Social and Health Services, Department of  
Southwest Air Pollution Control Authority  
Supreme Court, State  
Transportation Improvement Board  
Transportation, Department of  
Utilities and Transportation Commission  
Washington State Patrol  
Western Washington University  
Yakima Valley Community College

(Subject/Agency index at back of issue)  
This issue contains documents officially  
filed not later than March 24, 1999

AMENDATORY SECTION (Amending Order 124B, filed 12/27/90, effective 1/31/91)

**WAC 246-290-220 (~~Lead-in~~) Drinking water materials and additives.** (1) All materials shall conform to the ANSI/NSF Standard 61 if in substantial contact with potable water supplies. For the purposes of this section, "substantial contact" means the elevated degree that a material in contact with water may release leachable contaminants into the water such that levels of these contaminants may be unacceptable with respect to either public health or aesthetic concerns. It should take into consideration the total material/water interface area of exposure, volume of water exposed, length of time water is in contact with the material, and level of public health risk. Examples of water system components that would be considered to be in "substantial contact" with drinking water are filter media, storage tank interiors or liners, distribution piping, membranes, exchange or adsorption media, or other similar components that would have high potential for contacting the water. Materials associated with such components as valves, pipe fittings, debris screens, gaskets, or similar appurtenances would not be considered to be in substantial contact.

(2) Materials or additives in use prior to the effective date of these regulations that have not been listed under ANSI/NSF Standard 60 or 61 shall be allowed for their current applications until such time that the materials are scheduled for replacement, or that stocks of existing additives are depleted and scheduled for reorder.

(3) Any treatment chemicals, with the exception of commercially retailed hypochlorite compounds such as unscented Clorox, Purex, etc., added to water intended for potable use shall comply with ANSI/NSF Standard 60. The maximum application dosage recommendation for the product certified by the ANSI/NSF Standard 60 shall not be exceeded in practice.

(4) Any products used to coat, line, seal, patch water contact surfaces or that have substantial water contact within the collection, treatment, or distribution systems shall comply with the appropriate ANSI/NSF Standard 60 or 61. Application of these products shall comply with recommendations contained in the product certification.

(5) The department may accept continued use of, and proposals involving, certain noncertified chemicals or materials on a case-by-case basis, provided all of the following criteria are met:

(a) The chemical or material has an acknowledged and demonstrable history of use in the state for drinking water applications;

(b) There exists no substantial evidence that the use of the chemical or material has caused consumers to register complaints about aesthetic issues, or health related concerns, that could be associated with leachable residues from the material; and

(c) The chemical or material has undergone testing through a protocol acceptable to the department and has been found to not contribute leachable compounds into drinking water at levels that would be of public health concern.

(6) Any pipe, pipe fittings, solder, or flux used in the installation or repair of a public water system shall be lead-free(-);

(a) This prohibition shall not apply to leaded joints necessary for the repair of cast iron pipes(-); and

~~((2))~~ (b) Within the context of this section, lead-free shall mean:

~~((a))~~ (i) No more than eight percent lead in pipes and pipe fittings(-); and

~~((b))~~ (ii) No more than two-tenths of one percent lead in solder and flux.

NEW SECTION

**WAC 246-290-221 Water demand design criteria.** (1) Except as provided in this section, expanding systems shall use water demand design for average day demand (ADD), and peak periods of demand such as maximum day demand (MDD), and peak hourly demand (PHD) that are based upon actual metered water use records. The data collected shall be sufficient to account for seasonal or other cyclic changes in water demand, and shall correlate to the maximum number of full-time or part-time equivalent residential units in service at any time.

(2) For seasonally used, transitory noncommunity, or recreational developments the design for ADD, MDD, and PHD shall be based upon metered water uses whenever such data is available. The data must account for the daily population using the water over the time that records are collected, and must reflect the uses associated with maximum occupancy for the development. The design demands for these developments apply only to part-time uses, and may not be applied to structures or dwellings that can be permanently occupied.

(3) In the absence of metered use or other comparable information, the following sources of design information may be used:

(a) Comparable metered water use data from analogous water systems. Analogous systems are those with similar characteristics, such as demographics, housing sizes, income levels, lot sizes, climate, water pricing structure, conservation practices, use restrictions, and soils and landscaping; or

(b) Design criteria or guidelines in the most recent edition of the department manual for design of Group A public water systems.

(4) The design for water systems based upon metered water use records shall have an MDD no lower than three hundred fifty gallons per day per equivalent residential unit (ERU), except for the design of any expansion to an existing water system that has a minimum of two years of meter records that clearly demonstrate that a lower design value for MDD may be used without significant risk of pressure loss. The meter records must correlate the demand data to the actual level of occupancy for the periods covered by the records.

(5) The minimum water demand and duration required for fire flow and/or fire suppression storage shall be determined by the local fire control authority, or chapter 246-293 WAC for systems within the boundaries of a designated critical water supply service area (CWSSA). Public water sys-

PERMANENT